

ECLX387HD**electricCenter**
ACCESSORIES**Breaker Hold-Down**
For Type MP-T, MP-HT
and MP-MT Breakers

Same As: ■ LX387HD

**INSTALLATION INSTRUCTIONS****⚠ DANGER**

Hazardous Voltage.
Will cause death,
serious injury or substantial
property damage.

Turn off power supplying this
equipment before working inside.


Note: This instruction outlines the
recommended installation procedure.

For use only where specified on panel
label.

1. Turn off and lock off the power
supplying this equipment before
working inside.

**SAFETY INSTRUCTIONS**

2. With holddown locating pin
inserted into existing bridge hole,
press firmly against thumb pad until holddown
snaps over detent on breaker into locked
position.



NOTE: This kit is intended only for 70A
through 125A two-pole and 15A through 100A
three-pole Murray type MP-T breakers, and all
Murray type MP-HT and type MP-MT breakers
in Murray 12-42 circuit load centers.

Not for use in Murray Rock Solid load centers.

4810428 Rev.A