

CATALOG NUMBER

ECLX069M

electricCenter
ACCESSORIES

Ground Bar Kit 7 Position

Same As:

- LX069M
- LX069MU



GROUND BAR INSTALLATION INSTRUCTIONS



⚠ DANGER

Hazardous Voltage.
Will cause death, serious injury
or substantial property damage.

Turn off power supplying this
equipment before working inside.



SAFETY INSTRUCTIONS

APPROXIMATE LOCATION* OF EQPT. GROUND BAR
MTG. HOLES (2" CENTERS) WITHIN ENCLOSURE.

*NOTE: MAY VARY FROM ONE TO TWO PER DEVICE. "A"
OR "D" MOST LIKELY OCCUR IN SMALL ENCLOSURES.
"B" AND "C" COMBINATION ARE MORE TYPICAL.

REMOVE SCREWS, POSITION HOLES IN BRACKET
OVER MTG. HOLES IN PANEL BACKWALL AND
FASTEN DOWN.

IN SOME COMBINATION DEVICES, SCREWS ARE
PROVIDED WITH DEVICE. IN THESE CASES, DISCARD
SCREWS SUPPLIED WITH GROUNDING BAR, AND USE
#8 SCREWS PROVIDED WITH DEVICE.

**SEE WIRING DIAGRAM FOR WIRE RANGE SIZE AND
TIGHTENING TORQUE REQUIREMENTS.**

Note: This instruction outlines the
recommended installation procedure.
(TOP)

